



Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the LR Type Approval System.

This certificate is issued to:

COMPANY NAME Jo Bird & Co. Ltd.
Factory Lane
Bason Bridge
Somerset, TA9 4RN
United Kingdom (UK)

PLACES OF PRODUCTION Jo Bird & Co. Ltd.
Factory Lane
Bason Bridge
Somerset, TA9 4RN
United Kingdom (UK)

ARRK Tooling Development Limited.
(formerly Sermo TP UK Ltd.)
Langrish, Petersfield
Hampshire, GU32 1RL
United Kingdom (UK)

Trade Circle Technical Industries
P.O. Box 5639,
Al Quoz Industrial Area
Dubai, UAE

DESCRIPTION GRP Storage Cabinets for Fire and Safety Equipment

TYPE Firebird Cabinets – Single, Double, Roller Shutter Door and Chest
ToughStore Cabinets – 100 Series

APPLICATION For the storage of fire and safety equipment in marine, offshore and petrochemical installations

Certificate No. 15/20067

Issue Date 19 June 2015

Expiry Date 18 June 2020

Sheet 1 of 2



Miroslav Denev
Hamburg Technical Support Office
Lloyd's Register EMEA

*Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS*



STANDARD

British Standard BS EN 60529:1992

RATINGS

Cabinet Types	Enclosure
JB13 (Single Door) and similar products ⁽¹⁾	IP56
JB17 (Double Door) and similar products	IP56
JB72 (Chest) and similar products	IP56
JB82 (Single door) and similar products *	IP56
RS400 (Roller Shutter Door) and similar products	IP56
PB10 (Chest) and similar products ⁽²⁾	IP56
SOS 100 (Formerly TS100)	IP54

(1) After 3 minutes spray, 82.5 ml of water ingress

(2) After 3 minutes spray, 69.5 ml of water ingress

* Item JB82 only produced in Somerset

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No.: LDSO/ETS/TP/WP13994747/W03033765 dated 2 May 2013 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 00/00085(E5) to which this extension should be attached.

Certificate No. 15/20067
Issue Date 19 June 2015
Expiry Date 18 June 2020
Sheet 2 of 2



Miroslav Denev
Hamburg Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.