

Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/DE/4226-3-REV 0 Page 1/11
--	--

Manufacturer	Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH
	Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland


Concerned Equipment : Portable & Mobile Fire Extinguishers

Product Ranges :

- ✓ Powder Stored Pressure
- ✓ Powder Cartridge Operated
- ✓ Foam/Water Stored Pressure
- ✓ Foam/Water Cartridge Operated
- ✓ CO2


Types : see page 2/11 till 11/11


Used Standards : EN3.7:2004+A1:2007,EN3.8:2006&2021,EN3.9:2006, EN1866-1 :2007, EN1866-2 :2014

The manufacturer is allowed to affix the marine CE mark  followed by notified body identification n° to the approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in Module D are fully complied with.

The approval is valid until 16/10/2027

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN3/EN1866 standards and the Marine Equipment Directive 2014/90/EU as amended on basis of the documentation and samples supplied for review and approval.


Approval Date: 06/03/2023	Name : B.Neve, Ir	Position General Manager
Notified body identification number :	0029	Signature 
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE						Certificate N° 17/DE/4226-3-REV 0 Page 2/11	
Manufacturer			Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH			
			Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland			
Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°/approval n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	KS 5 BG (Steel & Alu)	5 kg CO2	SP41/95 03-6-021/N 244 03-6-957/N 263 96-23-88/N 88 99-23-30/N 156 94-23-1039/N 81 04-6-1485/N 275 05-6-3322/N 351 05-6-3697/N 354 06-6-3310/N 386 2007-F-0327/N 392 2008-F-0020/N 466 2008-F-0315/N 496 2009-F-0403/N 586 2011-F-1279/N 683 2011-F-2064/N 689 2011-F-2152/N 691 2011-F-4261/N 700-1 2011-F-4261/N 700-2 2012-F-0958/N 691-1 20170933/N 854 20190490/N874 2007-F-1871/N 471(-1) 20161242/N 842(-1)	89B	-30°C +60°C	216/220 bar (34CrMo4) 169,3 bar (AA6061)	315 bar (34CrMo4) 212 bar (AA6061)
FLN Neuruppin	KA 5 BG (Antimag)	5 kg CO2	SP66/93 10303311 ASD FR1 01 20151292/T 462 01-6-839/T 189 04-6-2260/T 250 06-6-2726/T 275 06-6-3331/I 64 06-6-3331/T 284 96-23-1044/T 92 2008-F-2386/T 266 2011-F-2459/T 389 2012-F-0090/T 397 93-23-536/T 18	89B	-30°C +60°C	169,3 bar	212 bar

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position : General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com




NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/DE/4226-3-REV 0 Page 3/11
--	--

Manufacturer	Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH
	Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland

Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	S 6 SK eco N	6l Foam Cartridge Operated (Water + KB152/16)	SP152/20 20200990/N 932	21A 183B	0°C +60°C	19,5 bar	30 bar
FLN Neuruppin	S 9 SK eco N	9l Foam Cartridge Operated (Water + KB152/16)	SP153/20 20200990/N 933	27A 233B	0°C +60°C	18,2 bar	30 bar
FLN Neuruppin	S 6 SKP eco N	6l Foam Cartridge Operated (H2O + KB153/16 + KB152/13)	SP150/20 20200990/N 930	34A – 183B	0°C +60°C	19,5 bar	30 bar
FLN Neuruppin	S 9 SKP eco N	9l Foam Cartridge Operated (H2O + KB153/16 + KB152/13)	SP151/20 20200990/N 931	43A – 233B	0°C +60°C	18,2 bar	30 bar
FLN Neuruppin	S 6 SKP HR N	6l Foam Cartridge Operated (H2O + KB153/16 + KB152/13)	SP149/20 20200990/N 913	43A – 233B	0°C +60°C	19,5 bar	30 bar
FLN Neuruppin	PG 6 Euro-S	6kg Powder Stored Pressure (Neutrex ABC40 Euro KB 127/12 & KB 127/13)	2013-F-0901/N 749-1 2013-F-0901/N 749	43A 233B	-30°C +60°C	20,5 bar	30 bar
FLN Neuruppin	PG 9 Euro-S	9kg Powder Stored Pressure (Neutrex ABC-Euro KB 127/13)	20141078/N 786-2 20141078/N 786-1	55A 233B	-30°C +60°C	20,5 bar	30 bar
FLN Neuruppin	PG 12 Euro-S	12kg Powder Stored Pressure (Neutrex ABC-Euro KB 127/13)	20141078/N 787-2 20141078/N 787-1	55A 233B	-30°C +60°C	20,5 bar	30 bar

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/DE/4226-3-REV 0 Page 4/11
--	--

Manufacturer	Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH
	Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland

Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	S 6 DN eco-classic N	6l Foam Stored Pressure (Water + KB152/13)	SP154/20 20200990/N 918	21A - 183B	0°C +60°C	18,4 bar	30 bar
FLN Neuruppin	S 9 DN eco-classic N	9l Foam Stored Pressure (Water + KB152/13)	SP155/20 20200990/N 919	27A - 233B	0°C +60°C	18,4 bar	30 bar
FLN Neuruppin	S 6 DN eco-premium N	6l Foam Stored Pressure (H2O + KB153/16 + KB152/13)	SP156/20 20200990/N 920	34A - 183B	0°C +60°C	18,4 bar	30 bar
FLN Neuruppin	S 9 DN eco-premium N	9l Foam Stored Pressure (H2O + KB153/16 + KB152/13)	SP157/20 20200990/N 921	43A - 233B	0°C +60°C	18,4 bar	30 bar
FLN Neuruppin	S 6 DN eco-HR	6l Foam Stored Pressure (Water + SP117/10)	SP170/10 2010-F-3216/N 661 2011-F-5226/N 716-1 2011-F-5226/N 716-2 2010-F-3937/N 665 20180037/N 860	34A - 144B	0°C +60°C	17,5 bar	30 bar
FLN Neuruppin	S 9 DN eco-HR	9l Foam Stored Pressure (H2O + SP117/10)	SP158/10 2010-F-3937/N 666 2010-F-3216/N 662 2011-F-5226/N 715-1 2011-F-5226/N 715-2	55A - 233B	0°C +60°C	18,4 bar	30 bar
FLN Neuruppin	S 9 DF-1	9l Foam Stored Pressure (H2O + SP48/03) (H2O + SP02/98) (H2O + KB186/13)	SP23/02 02-6-1513/N 247 02-6-568/N 231 2007-F-4570_N 491 2007-F-1871/N 565 20141079/N 801-2 20141079/N 801-1 05-6-1778/N 315 2013-F-3824/N 766	27A - 183B	-30°C +60°C	18,5 bar	30 bar

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position : General Manager
Notified body identification number : 0029	Signature : 	
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com




NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/DE/4226-3-REV 0 Page 5/11
--	--

Manufacturer	Name FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland
	Address	


Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	FluorineFree 06 FC	6l Foam Cartridge Operated (KB34/21)	SP187/20 20201268/N 885	27A 144B	0°C +60°C	17 bar	30 bar
FLN Neuruppin	FluorineFree 09 FC	9l Foam Cartridge Operated (KB34/21)	SP188/20 20201269/N 886	43A 183B	0°C +60°C	17 bar	30 bar
FLN Neuruppin	FluorineFree 06 FS	6l Foam Stored Pressure (KB34/21)	SP189/20 20201268/N 894	27A - 144B	0°C +60°C	17 bar	30 bar
FLN Neuruppin	FluorineFree 09 FS	9l Foam Stored Pressure (KB34/21)	SP190/20 20201269/N 895	43A 183B	0°C +60°C	17 bar	30 bar
FLN Neuruppin	FluorineFree 06 FCC	6l Foam Cartridge Operated (KB175/22 + KB174/22)	SP136/22 20220509/N 937.1	27A - 144B	+5°C +60°C	18,0 bar	30 bar
FLN Neuruppin	FluorineFree 09 FCC	9l Foam Cartridge Operated (KB175/22 + KB174/22)	SP137/22 20220516/N 940	34A - 183B	+5°C +60°C	18,0 bar	30 bar


Approval Date : 06/03/2023	Name : B.Neve, Ir	Position General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com




NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE						Certificate N°	
In accordance with module B of the Marine Equipment Directive						17/DE/4226-3-REV 0	
2014/90/EU as amended						Page 6/11	
Manufacturer			Name		FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH		
			Address		Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland		
Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	PG 6 PDY	6kg Powder Stored Pressure (Neutrex Super SP 89/08) (Neutrex C PL-1/03) (Neutrex ABC40 PL-3/92)	SP38/95 02-6-252/N 241 98-23-195/N 124 94-23-1039/N 78 2000-23-898/N 189 06-6-3065/N 415 2007-F-1871/N 475 20151212/N 831-2 20151212/N 831-1 2011-F-5227/N 701 04-6-1485/N 273 2008-F-2261/N 524 20141080/N 803 2011-F-5226_N 723-1 2011-F-5226_N 723-2	55A 233B	-30°C +60°C	20,5 bar	30 bar
FLN Neuruppin	PG 9 PDY	9kg Powder Stored Pressure (Neutrex Super SP 89/08) (Neutrex C PL-1/03) (Neutrex ABC40 PL-3/92)	SP47/93 02-6-252/N 242 94-23-1039/N 55 98-23-195/N 125 92-23-43/N 10 2000-23-898/N 190 05-6-1464/N 327 06-6-3065/N 416 2007-F-1871/N 479 04-6-1485/N 284 2008-F-2261/N 525 20141080/N 804	55A 233B	-30°C +60°C	20,5 bar	30 bar
FLN Neuruppin	PG 12 PDY	12kg Powder Stored Pressure (Neutrex Super SP 89/08) (Neutrex C PL-1/03) (Neutrex ABC40 PL-3/92)	SP32/98 02-6-252_N 208 98-23-195_N 126 04-6-1485_N 279 05-6-1464_N 328 06-6-3065_N 417 2007-F-1871/N 483 20151212/N 832-2 20151212/N 832-1 04-6-1485/N 279 2008-F-2261/N 538 20141080/N 805	55A 233B	-30°C +60°C	20,5 bar	30 bar
FLN Neuruppin	P 12 DK/P 12 DKX	12kg Powder Stored Pressure (BC 101 K PL-7/77)	SP17/15 20141705/N 823 20141705/N 819	233B	-30°C +60°C	17 bar	30 bar
Approval Date : 06/03/2023			Name : B.Neve, Ir		Position General Manager		
Notified body identification number : 0029			Signature 				
Notified body stamp : APRAGAZ VZW / ASBL							
Notified body reference : P17348/000							




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE				Certificate N°			
In accordance with module B of the Marine Equipment Directive				17/DE/4226-3-REV 0			
2014/90/EU as amended				Page 7/11			
Manufacturer		Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH				
Address		Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland					
Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	Baseline 04 PS	4kg Powder Stored Pressure (SP134/07)	SP207/20 20210608/N897.1	21A 133B	-30°C +60°C	17,9 bar	30 bar
FLN Neuruppin	Baseline 06 PS	6kg Powder Stored Pressure (KB218/14)	SP208/20 20201296/N887.1 20210399/N 896	43A 233B	-30°C +60°C	17,3 bar	30 bar
FLN Neuruppin	Baseline 09 PS	9kg Powder Stored Pressure (KB218/14)	SP209/20 20201296/N888.1	43A 233B	-30°C +60°C	18 bar	30 bar
FLN Neuruppin	Baseline 12 PS	12kg Powder Stored Pressure (KB218/14)	SP210/20 20201296/N889.1	55A 233B	-30°C +60°C	18 bar	30 bar
FLN Neuruppin	WD3F-500 2% -30	3l Wasser (& F-500) Stored Pressure (SP83/08 + KB38/14)	SP104/20 20200592/N 881	13A	-30°C +60°C	17,1 bar	30 bar
FLN Neuruppin	WD6F-500 2% -30	6l Wasser (& F-500) Stored Pressure (SP83/08 + KB38/14)	SP82/20 20191327/N 880	27A	-30°C +60°C	18,3 bar	30 bar
FLN Neuruppin	WD9F-500 2% -30	9l Wasser (& F-500) Stored Pressure (SP83/08 + KB38/14)	SP105/20 20200592/N 882	34A	-30°C +60°C	18,1 bar	30 bar
FLN Neuruppin	WA9F-500 2% -30	9l Wasser (& F-500) Cartridge Operated (KB108/21)	SP07/21 20200921/N 902	34A	-30°C +60°C	17 bar	30 bar

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position : General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	




Chaussée de Vilvorde, 156
 Vilvoordsesteenweg 156
 B-1120 Bruxelles/Brussel
 Tel.: +32 (0)2 264 03 60
 Fax: +32 (0)2 268 89 58
 www.apragaz.com
 info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/DE/4226-3-REV 0 Page 8/11
--	--

Manufacturer	Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH
	Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland

Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	W 6 DS N	6l Water Stored Pressure (KB153/16)	SP144/20 20200990/N 906	43A	0°C +60°C	18,2 bar	30 bar
FLN Neuruppin	W 9 DS N	9l Water Stored Pressure (KB153/16)	SP145/20 20200990/N 907	55A	0°C +60°C	18,2 bar	30 bar
FLN Neuruppin	W 6 SKS N	6l Water Cartridge Operated	SP147/20 20200990/N 925	43A	0°C +60°C	19,5 bar	30 bar
FLN Neuruppin	W 9 SKS N	9l Water Cartridge Operated	SP148/20 20200990/N 926	55A	0°C +60°C	18,2 bar	30 bar
FLN Neuruppin	FX 6	6kg Powder Stored Pressure (SP89/08, PL12/90)	SP32/01 01-6-1329/T 190 03-6-046/T 204 06-6-3065/N 163 06-6-3065/N 425 2008-F-3236/T 316 01-6-229/T 163	43A 233B	-30°C +60°C	18 bar	30 bar
FLN Neuruppin	F-500 Tandem 09 WS 2% -30 °C	9l Wasser (& F-500) Stored Pressure (SP83/08 + KB38/14)	SP25/21 20210268/N 893	34A	-30°C +60°C	18,5 bar	30 bar

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



084 - PROD
17065

NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE						Certificate N°		
In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended						17/DE/4226-3-REV 0		
Manufacturer			Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH				
			Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland				
Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)	
FLG Neuruppin	PG 1 E	1kg Powder Stored Pressure (Neutrex ABC85 – SP35/06)	2007-F-1871/N 485 2008-F-0064/N 467	8A 34B C	-30°C +60°C	20,5 bar	30 bar	
FLG Neuruppin	PG 2 ES	2kg Powder Stored Pressure (Neutrex ABC85 – SP35/06)	2007-F-1871/N 486 2008-F-0064/N 468 2011-F-5230/N 703	13A 89B C	-30°C +60°C	20,5 bar	30 bar	
FLG Neuruppin	PG 6 DX	6kg Powder Stored Pressure (Neutrex super – SP89/08)	20151212/N 831-1 20151212/N 831-2	55A 233B	-30°C +60°C	20,5 bar	30 bar	
FLG Neuruppin	KS 2 BG (Steel & Alu)	2 kg CO2	2007-F-1871/N 470 2007-F-1871/N 470-1 03-6-021/N243 zum 03-6-957/N262 zum 94-23-1039/N 80 20151791/N 835 20170932/N 853 04-6-1485/N 272 05-6-3697/N 353 05-06-2617/N 444 2007-F-0327/N 391 2011-F-1279/N 682 2011-F-2064/N 688 2011-F-4261/N 699-1 2011-F-4261/N 699-2 2012-F-0958/N 690-1 20151791/N 835 20170932/N 853 20190490-N873	34B	-30°C +60°C	216/220 bar (34CrMo4) 169,3 bar (AA6061)	315 bar (34CrMo4) 212 bar (AA6061)	
FLN Neuruppin	Metal 12 PC	12kg Powder Stored Pressure (KB68/14)	SP101/19 20190894/N 877	D	-30°C +60°C	18 bar	30 bar	

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position : General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp : APRAGAZ VZW / ASBL		
Notified body reference : P17348/000		



Chaussée de Vilvorde, 156
 Vilvoordsesteenweg 156
 B-1120 Bruxelles/Brussel
 Tel.: +32 (0)2 264 03 60
 Fax: +32 (0)2 268 89 58
 www.apragaz.com
 info@apragaz.com





084 - PROD
17065

NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/DE/4226-3-REV 0 Page 10/11
--	---

Manufacturer	Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH
	Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland

Mark	Type	Nominal charge	EN3.7/EN3.8/EN3.9 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLG Neuruppin	S 6 SKF-1	6l Foam Cartridge Operated (Neufoam FO-Premix MG6-30-KB186-13)	2013-F-1495/N 754-1 2013-F-1495/N 754-2	21A 144B	-30°C +60°C	20,5 bar	30 bar
FLG Neuruppin	WD 9 F-500	9l Water Stored Pressure (H2O + F-500 -SP83/08)	2007-F-1871/N 574 2011-F-5226/N 710-2 20170509/N 850 20141079/N 789-2	27A	+5°C +60°C	20,5 bar	30 bar
FLG Neuruppin	F 6 L	6l Water Stored Pressure (H2O + Neufrol M - PL-12/87)	2007-F-1871/N 577 2011-F-5226/N 713-1 2011-F-5226/N 713-2 EH 09 0401 1070 05-6-1778/N 320 2007-F-1148/N 438 2009-F-3743/N 610 2013-F-3824/N 770	13A 75F	0°C +60°C	20,5 bar	30 bar
FLG Neuruppin	WA 9 F-500	9l Water Cartridge Operated (H2O + F-500 -SP83/08)	2010-F-0304/N 641 20151064/N 828 2009-F-4710/N 627 2013-F-0267/N 748	27A	+5°C +60°C	20,5 bar	30 bar
FLG Neuruppin	S 2 DF-1	2l Foam Stored Pressure (Neufoam FO-KB186-13) (Neufoam F -SP02/98) (Neufoam FX -SP48/03)	2007-F-1871/N 530 2013-F-3824/N 764 05-6-1778/N 313	5A 34B	-30°C +60°C	20,5 bar	30 bar
FLG Neuruppin	S 6 DF-1	6l Foam Stored Pressure (Neufoam FO-KB186-13) (Neufoam F -SP02/98) (Neufoam FX -SP48/03)	2007-F-1871/N 564 20141079/N 800-2 2013-F-3824/N 765 05-6-1778/N 314	21A 144B	-30°C +60°C	20,5 bar	30 bar

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position General Manager
Notified body identification number :	0029	Signature 
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com




NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/DE/4226-3-REV 0 Page 11/11
--	---

Manufacturer	Name	FLN Feuerlöschgeräte Neuruppin Vertriebs-GmbH
	Address	Martin-Ebell-Strasse 4 D-16816 Neuruppin Deutschland

Mark	Type	Nominal charge	EN1866 test report n°	Fire Classes	Operation T° range	Working Pressure at T° max	Test Pressure (PT)
FLN Neuruppin	PG 50 A	50kg Powder Cartridge Operated (PL-9/58)	SP72/06 06-6-3067/N 364 20061221/N 364	A IIB	-30°C +60°C	15,5 bar	30 bar
FLN Neuruppin	PG 50 LM	50kg Powder Stored Pressure (KB115/12)	20190233/MB 43 2012-F-0080/MB08	A IIIB	-30°C +60°C	14 bar	30 bar
FLN Neuruppin	WA50F-500 2% -30°C	50l Foam Cartridge Operated (KB108/22)	SP08/21 20200922/N904	A	-30°C +60°C	10 bar	30 bar
FLN Neuruppin	FluorineFree 50W	50l Foam Cartridge Operated (SP138/22)	20220524/N938 20220651/N939	A IIB	+5°C +60°C	10 bar	30 bar

--

Approval Date : 06/03/2023	Name : B.Neve, Ir	Position : General Manager
Notified body identification number : 0029	Signature 	
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P17348/000	