

CERTIFICATE OF CONFORMITY – FOAM CONCENTRATES

Certificate of conformity reference number: **KB 290/14**

Test specification: **EN 1568-1 : 2008, EN 1568-3 : 2008**

Test report no.: **2012-F-1119/Sth 139**

Requested by: **Fabrik chemischer Präparate von Dr. Richard Sthamer GmbH & Co. KG
Liebigstraße 5, 22113 Hamburg**

Manufacturer: **Fabrik chemischer Präparate von Dr. Richard Sthamer GmbH & Co. KG
Liebigstraße 5, 22113 Hamburg**

Product name: **STHAMEX-AFFF 3% F-15 #4341**

Grade of foam concentrate: **Aqueous film-forming foam concentrate (AFFF) according to annex A EN 1568**

Test fire performance: **Extinguishing performance and burn-back resistance:
Medium expansion foam according to EN 1568-1 (3%)
with potable water / with simul. sea water:
The requirements for medium expansion foam are met.
Low expansion foam according to EN 1568-3 (3%)
with potable water / with simulated sea water: **I B / I B****

Freezing point: **- 15 °C**

Notes: **–**


Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for foam concentrates which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

15th January 2015



Grad. Eng. Jürgen Dittrich
Laboratory Manager

