


Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



EU TYPE EXAMINATION CERTIFICATE – Design Type		Certificate N°
In accordance with the requirements of Module B of the Pressure Equipment Directive 2014/68/EU		23/IT/5038-1-REV 1
Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 I-27020 Torre d’Isola (Pavia) ITALY
Concerned Equipment: Cartridge Operated Steel Water Based - Portable Fire Extinguishers & Related Cylinders		
Type: Group CO-ST-WB		
a) FG6-F-FF-F XF (revisie C – 07/02/2024) WG6-F-FA-FP-F Li (revisie C – 07/02/2024) c) FG9-F-FF-F XF (revisie C – 07/02/2024) WG9-F-FA-FP-F Li (revisie C – 07/02/2024)		
Capacities: 6 – 9 l		
Set pressure at 60°C: max. 18 bar		
Test pressure: 27 bar		
Service temperature range: +5°C/+60°C (WG6-F & WG9-F) ; +0°C/+60°C (all others)		
Used Standard : EN3.7:2004 A1:2007 & EN3.8:2021		
<p>The manufacturer is allowed to affix the “CE” mark followed by the notified body identification n°, to the approved equipment under the conditions described in article 19 of the Directive and only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 09/02/2033</p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/EU, certifies that the design of these pressure vessels conforms to the relevant requirements of the pertinent EN3 standards in force and the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.</p>		
Approval Date : 17/09/2024	Name : Ir. B. NEVE	Position General Manager
Notified body identification number :	0029	Signature 
Notified body:	APRAGAZ VZW / ASBL	
Notified body reference :	P4434/000	