A P R A G A Z
a.s.b.l.
Your Inspection Authority

Member of TIC COUNCIL

J PS6-HH
PS

Chaussée de Vilvorde, 156 B-1120 Brussels
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

ANAF FIRE PROTECTION S.p.A.
Via del Commercio 4
IT- 27020 TORRE D'ISOLA

Y/Ref. :
O/Ref. : VDS/BG

27 May 2024

APPROVAL CERTIFICATE EN 3-7 – PORTABLE FIRE EXTINGUISHERS FOR BUILDINGS

We hereby declare that the hereafter mentioned extinguishers were type approved according to the requirements of the EN 3-7 standards, according to the tests reports and with the hereafter mentioned approval number:

Approval No.	Brand	Type	Nominal charge	Fire ratings achieved	EN 3-7 test report No.
EN3-24/546	ANAF	FG6-F XF	5,61 l water + 0,3 l FFX Booster A + 0,09 l FFX Compact	21 A - 144 B	EN 12502
EN3-24/547	ANAF	FG9-F XF	8,415 l water + 0,450 l FFX Booster A + 0,135 l FFX Compact	27 A - 183 B	EN 12505

The approval is subject to the continued maintenance of the Quality System of the manufacturer in accordance with the relevant requirements of EN 3-10.

The manufacturer is authorized to affix the above mentioned approval number on the marking label of the approved corresponding extinguishers as long as the results of our inspections, periodically made according to the requirements of § 10 of the EN 3-10, are satisfactory.

Nota Bene: additional requirements (i.e. language of the labels, maintenance requirements, ...) may be made by national regulations and/or quality marks.

Head of Fire Extinguisher Depart.

Christophe Vanderschrieck