APRAGAZ
Our stamp, your safety

Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com

BELAC
084 - PROD
17065

NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE **In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended**	**Certificate N°** **14/IT/3349-2-REV 0**

Manufacturer	Name	**ANAF FIRE PROTECTION S.P.A.**
	Address	**Via del Commercio 4** **IT - 27020 Torre d'Isola (Pavia)** **ITALY**

Concerned Equipment: Portable Fire Extinguishers (Powder Stored Pressure)

Type :

a) PS6-HH ABC according to technical design ref. PP.895E.F000.00
b) PS6-HHZ ABC according to technical design ref. PP.897E.F000.00

Capacities: 6 kg

Set pressure: max. 15 bar (+60°C)
PS : 15,38 bar
Test pressure: 22 bar
Service temperature range: min. -30°C / max. +60°C
Used Standards : EN3.7:2004 A1:2007 & EN3.8:2021

The manufacturer is allowed to affix the marine CE mark (followed by NOBO n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in module D are fully complied with.

The approval is valid until 02/03/2028

APRAGAZ acting within the scope of its notification for the purpose of the European council directive 2014/90/EU, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN3 standards and the Marine Equipment Directive 2014/90/EU as amended on basis of the documentation and samples supplied for review and approval.

Approval Date : **05/06/2023** Name : **B.Nève, Ir.** Position **General Manager**

Notified body identification number : **0029** Signature

Notified body stamp : **APRAGAZ VZW / ASBL**

Notified body reference : **P4434/000**