APRAGAZ
Our stamp, your safety

Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com

BELAC
084 - PROD
17065

| EU TYPE EXAMINATION CERTIFICATE – Design Type<br>In accordance with the requirements of Module B of the Pressure Equipment Directive 2014/68/EU | Certificate N°<br>23/IT/5031-0-REV 0 |
|---|---|

| | | |
|---|---|---|
| **Manufacturer** | Name | **ANAF FIRE PROTECTION S.P.A.** |
| | Address | **Via del Commercio 4**<br>**I-27020 Torre d'Isola (Pavia)**<br>**ITALY** |

**Concerned Equipment:** Stored Pressure Aluminum Water Based - Portable Fire Extinguishers & Related Cylinders

**Type**: Group SP-AL-WB

a) **FS2**-Y-P; **WS2**-YP; **WS2**-Y LI (revisie A – 28/10/2022)
b) **FS6**-EVF-JM-JMF-JMZ-JMFZ-J-JF-LH-LHF-LHZ-LHFZ (revisie A – 28/10/2022)
**WS6**-JMA-JMP-JM-JM LI- JMAZ-JMPZ-JMZ-JMZ LI-JA-JP-J-J LI-LHA-LHP-LH-LH LI- LHAZ-LHPZ-LHZ-LHZ LI (revisie A – 28/10/2022)
c) **FS9**-EV-JM-JMF-JMZ-JMFZ-J-JF-LH-LHF-LHZ-LHFZ (revisie A – 28/10/2022)
**WS9**-JMA-JMP-JM-JM LI- JMAZ-JMPZ-JMZ-JMZ LI-JA-JP-J-J LI-LHA-LHP-LH-LH LI- LHAZ-LHPZ-LHZ-LHZ LI (revisie A – 28/10/2022)

**Capacities**: 2 - 6 – 9 l
**Set pressure at 60°C**: max. 13,98 bar (2l) - max. 17,48 bar (FS6-EVF & all 9 l) - max. 15,38 bar (all other 6 l)
**Test pressure**: 20 bar (2l) – 25 bar (FS6-EVF & all 9 l) - 22 bar (all other 6 l)
**Service temperature range**: 5°C/+60°C (J-JM-JMZ-LH-LHZ) ; 0°C/+60°C (all others)
**Used Standard :** EN3.7:2004 A1:2007 & EN3.8:2021

The manufacturer is allowed to affix the "CE" mark followed by the notified body identification n°, to the approved equipment under the conditions described in article 19 of the Directive and only if the requirements stated in module D are fully complied with.

**The approval is valid until 06/02/2033**

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/EU, certifies that the design of these pressure vessels conforms to the relevant requirements of the pertinent EN3 standards in force and the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.

Approval Date : **06/02/2023** Name : **Ir. B. NEVE** Position **General Manager**

Notified body identification number : **0029** Signature

Notified body: **APRAGAZ VZW / ASBL**

Notified body reference : **P4434/000**