



CNBOP-PIB

YOUR PARTNER IN  
**SAFETY**

SCIENTIFIC AND RESEARCH CENTRE  
FOR FIRE PROTECTION  
NATIONAL RESEARCH INSTITUTE

BU/0676/203/<sup>8/13</sup> /2023

September 15<sup>th</sup>, 2023.

**Fabrik chemisher Präparate  
Von Dr. Richard Sthamer GmbH & Co. KG  
Liebigstraße 5  
22113 Hamburg  
Deutschland  
e-mail: C.Brand@sthamer.com**

Laboratory of Fire Extinguishing Agents and Equipment of Scientific and Research Centre for Fire Protection National Research Institute inform that analysis of STHAMEX<sup>®</sup> MARINE 3% F-20 #9372 covered by contract No. 1319/BU/23 have been completed. The sample of the foam extinguishing agent: STHAMEX<sup>®</sup> MARINE 3% F-20 #9372 presented for testing meets the requirements of the standard IMO Msc.1/Circ. 1312.

Information has been prepared for customer demand.

Sincerely

KIEROWNIK  
ZESPOŁU LABORATORIÓW BU  
  
mgr Justyna Gniazdowska

Notified body in the European Union no. 1438

QMS compliant with the requirements of PN-EN ISO 9001:2015-10

Product Certification Body accredited by Polish Centre for Accreditation, no. AC 063

Testing laboratories accredited by Polish Centre for Accreditation: nos. AB 059, AB 060, AB 207, AB 1280

PS/12/30.04.2014  
ul. Nadwiślańska 213, 05-420 Józefów, Poland Tel. +48 22 769 32 73 Fax +48 22 769 33 73 www.cnbop.pl cnbop@cnbop.pl  
KRS: 0000149404 REGON: 000591685 VAT 532-18-29-288

