





Chaussée de Vilvorde, 156
 Vilvoordsesteenweg 156
 B-1120 Bruxelles/Brussel
 Tel.: 32 (0)2 264 03 60
 Fax: 32 (0)2 268 89 58
 http://www.apragaz.com
 info@apragaz.com



EC TYPE - EXAMINATION		Certificate N°
In accordance with module B of Directive 2014/90/EU on Marine Equipment		20/IT/4694-0-REV 0
Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 IT - 27020 Torre d'Isola (Pavia) ITALY
Concerned Equipment: Portable Fire Extinguishers (Water Based Stored Pressure)		
Type: FS9-LH & FS9-LHZ / FS9-LHF & FS9-LHFZ		
Technical documents ref.: 09.886F.F000.00 & 09.888F.F000.00 / 09.896F.F000.00 & 09.898F.F000.00		
Capacities: 9l Fire Rating : 34A - 233B / 34A - 233B - 75F		
Set pressure: max. 17,48 bar (+60°C) Test pressure: 25 bar		
Bursting pressure: ≥55 bar		
Service temperature range: min. +0°C / max. +60°C		
<p>The manufacturer is allowed to affix the marine CE mark  (followed by the NoBo n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 02/11/2025</p>		
<p>APRAGAZ, acting within the scope of its notification for the above mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 & EN 3.8 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.</p>		
Date : 02/11/2020	Name : B. NEVE, ir	Position General Manager
Notified body identification number :	0029	Signature 
Notified body :	APRAGAZ VZW / ASBL	
Notified body reference :	4434 P 000	