





Chaussée de Vilvorde, 156
 Vilvoordsesteenweg 156
 B-1120 Bruxelles/Brussel
 Tel.: 32 (0)2 264 03 60
 Fax: 32 (0)2 268 89 58
 http://www.apragaz.com
 info@apragaz.com



EC TYPE - EXAMINATION		Certificate N°
In accordance with module B of Directive 2014/90/EU on Marine Equipment		16/IT/3936-1-REV 0
Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 IT - 27020 Torre d'Isola (Pavia) ITALY
Concerned Equipment: Portable Fire Extinguishers (Powder Stored Pressure)		
Type:		
a) PS9-HH ABC according to technical design ref. 32.895F.F000.00 Rev D		
b) PS9-HHZ ABC according to technical design ref. 32.897F.F000.00 Rev D		
Capacities: 9 kg		
Design pressure Ps : max. 15,38 bar (+60 °C)		
Test pressure: 22 bar		
Bursting pressure: ≥55 bar		
Service temperature range: min. -30 °C / max. +60 °C		
Used Standards : EN3.7 & EN3.8		
<p>The manufacturer is allowed to affix the marine wheel mark  (followed by the NoBo identification n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 05/06/2026</p>		
<p>APRAGAZ, acting within the scope of its notification for the above mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 & EN 3.8 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.</p>		
Approval Date : 08/12/2021	Name : Ir. B. NEVE	Position General Manager
Notified body identification number :	0029	Signature 
Notified body stamp :	APRAGAZ VZW / ASBL	
Notified body reference :	P4434/000	