APRAGAZ

Member of CEOC INTERNATIONAL

Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com

BELAC Cert N°084-PROD

NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended	Certificate N° 17/IT/4185-0-REV 0

Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 I-27020 Torre d'Isola (Pavia) ITALY

Concerned Equipment: Portable Fire Extinguishers (Powder or Water Based Stored Pressure)

Type: a) WS9-J according tech. designation 08.860F.F000.00 and bottle 00.805F.7895 CE
b) WS9-LH according tech. designation 08.886F.F000.00 and bottle 00.805F.7895 CE
b) WS9-LHZ according tech. designation 08.888F.F000.00 and bottle 00.805F.7895 CE

Capacities: 9 L

Set pressure: PS ≤ 17,48 bar

Test pressure: 25 bar

Service temperature range: +5 °C / +60 °C

The manufacturer is allowed to affix the Mark ⊛ to the approved equipment under the conditions described in article 10 of the Directive and only if the requirements stated in module D are fully met.

The approval is valid until 06/08/2023.

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the types of these pressure vessels conform with the relevant requirements of the pertinent EN 3 standards in force and the Marine Equipment Directive 2014/90/EU on bases of the documentation and samples supplied for review and approval.

Date : **07/08/2017** Name : **Ch. Leplat** Position **General Manager**

P.O. B. NEVE

Notified body identification number : **0029**

Signature

Notified body stamp : **APRAGAZ Belgium Inspecting Authority**

Notified body reference : **P4434/000**