

CERTIFICATE OF CONFORMITY – FOAM CONCENTRATES

Certificate of conformity reference number: **KB 123/15**

Test specification: EN 1568-3: 2008

Test report no.: 20150412/Sth 213

Requested by: Fabrik chemischer Präparate von Dr. Richard Sthamer GmbH & Co. KG
Liebigstraße 5, 22113 Hamburg

Manufacturer: Fabrik chemischer Präparate von Dr. Richard Sthamer GmbH & Co. KG
Liebigstraße 5, 22113 Hamburg

Name of the fire extinguishing medium: STHAMEX-AFFF 3% F-25 #4344

Grade of foam concentrate: Aqueous film-forming foam concentrate (AFFF)
according to annex A EN 1568

Test fire performance: Extinguishing performance and burn-back resistance:
Low expansion foam according to EN 1568-3 (3%)
with potable water / with simulated sea water: **IA / IA**

Freezing point: - 25 °C

Notes: This concentrate can require special proportioning equipment.


Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for foam concentrates which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

29th June 2015



Grad. Eng. Jürgen Ditttrich
Laboratory Manager

